UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110904

Glendale School District	Project: General	Date Reported: 12/22/20
PO Box E/10598	Project #: Glendale High School / Lead	Date Received: 11/09/20 09:19
Glendale, OR 97442		Sampled By: Clinton Crites
	Client Contact: David Hanson	

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
0110904-01	Sample Location: Glendale High School Kitchen / Sink 1									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 11:20	12/18/20	DST	
0110904-02	Sample Location: Glendale High School Kitchen / Sink 2									
Lead (‡)		1030	4	ppb	2	15	11/02/20 11:20	12/18/20	DST	
0110904-03	Sample Location: Glendale High School Kitchen / Sink 3									
Lead (‡)		1030	5	ppb	2	15	11/02/20 11:21	12/18/20	DST	
0110904-04	Sample Location: Glendale High School Kitchen / Sink 4									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 11:21	12/18/20	DST	
0110904-05	Sample Location: Glendale High School Kitchen / Sink 5									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 11:21	12/18/20	DST	
0110904-06	Sample Location: Glendale High School Drinking Fountain / West Wall									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:04	12/18/20	DST	
0110904-07	Sample Location: Glendale High School Girls Locker Room									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 13:55	12/18/20	DST	
0110904-08	Sample Location: Glendale High School Boys Locker Room									
Lead (‡)		1030	9	ppb	2	15	11/02/20 13:56	12/18/20	DST	
0110904-09	Sample Location: Glendale High School Team Locker Room									
Lead (‡)		1030	8	ppb	2	15	11/02/20 13:59	12/18/20	DST	
0110904-10	Sample Location: Glendale High School Office / Sink									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:00	12/18/20	DST	
0110904-11	Sample Location: Glendale High School Drinking Fountain / 1 Main Hall									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:05	12/18/20	DST	
0110904-12	Sample Location: Glendale High School Gym / Drinking Fountain									
Lead (‡)		1030	4	ppb	2	15	11/02/20 13:56	12/18/20	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110904

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
0110904-13	Sample Location: Glendale High School Concessions / Sink									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:00	12/18/20	DST	
0110904-14	Sample Location: Glendale High School Student Center / Sink									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:27	12/18/20	DST	
0110904-15	Sample Location: Glendale High School Main Hallway / Drinking Fountain 2									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:30	12/18/20	DST	
0110904-16	Sample Location: Glendale High School Home EC / Sink 1									
Lead (‡)		1030	5	ppb	2	15	11/02/20 14:31	12/18/20	DST	
0110904-17	Sample Location: Glendale High School Home EC / Sink 2									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:31	12/18/20	DST	
0110904-18	Sample Location: Glendale High School Home EC / Sink 3									
Lead (‡)		1030	14	ppb	2	15	11/02/20 14:32	12/18/20	DST	
0110904-19	Sample Location: Glendale High School Home EC / Sink 4									
Lead (‡)		1030	14	ppb	2	15	11/02/20 14:33	12/18/20	DST	
0110904-20	Sample Location: Glendale High School Home EC / Sink 5									
Lead (‡)		1030	ND	ppb	2	15	11/02/20 14:34	12/18/20	DST	
0110904-21	Sample Location: Glendale High School Home EC / Sink 6									
Lead (‡)		1030	4	ppb	2	15	11/02/20 14:36	12/18/20	DST	
0110904-22	Sample Location: Glendale Jr High Drinking Fountain									
Lead (‡)		1030	3	ppb	2	15	11/02/20 14:40	12/18/20	DST	
0110904-23	Sample Location: Glendale High School Ice Machine									
Lead (‡)		1030	**55**	ppb	2	15	11/03/20 08:41	12/18/20	DST	
0110904-24	Sample Location: Glendale High School Bus Barn / Sink									
Lead (‡)		1030	ND	ppb	2	15	11/03/20 08:52	12/18/20	DST	
0110904-25	Sample Location: Glendale High School Football Field / Drinking Fountain									
Lead (‡)		1030	12	ppb	2	15	11/03/20 08:57	12/18/20	DST	
0110904-26	Sample Location: Glendale High School Football Concessions / Sink									
Lead (‡)		1030	**21**	ppb	2	15	11/03/20 09:17	12/18/20	DST	
0110904-27	Sample Location: Glendale High School Softball Concessions / Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110904

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (‡)		1030	**143**	ppb	2	15	11/03/20 10:10	12/18/20	DST	
0110904-28	Sample Location: Glendale High School Softball Drinking Fountain									
Lead (‡)		1030	11	ppb	2	15	11/03/20 10:10	12/18/20	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110904

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager