UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110903

Glendale School District	Project: General	Date Reported:	12/22/20
PO Box E/10598	Project #: Glendale Elementary School / Lead	Date Received:	11/09/20 09:19
Glendale, OR 97442		Sampled By:	Clinton Crites
	Client Contact: David Hanson		

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
0110903-01	Sample Location: GES Room 110 / Fountain									
Lead (‡)		1030	10	ppb	2	15	11/04/20 06:37	12/18/20	DST	
0110903-02	Sample Location: GES Room 111 / Fountain									
Lead (‡)		1030	7	ppb	2	15	11/04/20 06:37	12/18/20	DST	
0110903-03	Sample Location: GES Room 112 / Fountain									
Lead (‡)		1030	6	ppb	2	15	11/04/20 06:40	12/18/20	DST	
0110903-04	Sample Location: GES Room 113 / Fountain									
Lead (‡)		1030	9	ppb	2	15	11/04/20 06:40	12/18/20	DST	
0110903-05	Sample Location: GES Room 114 / Fountain									
Lead (‡)		1030	ND	ppb	2	15	11/04/20 06:42	12/18/20	DST	
0110903-06	Sample Location: GES Room 115 / Fountain									
Lead (‡)		1030	5	ppb	2	15	11/04/20 06:42	12/18/20	DST	
0110903-07	Sample Location: GES Room 116 / Fountain									
Lead (‡)		1030	ND	ppb	2	15	11/04/20 06:50	12/18/20	DST	
0110903-08	Sample Location: GES Room 117 / Fountain									
Lead (‡)		1030	4	ppb	2	15	11/04/20 06:50	12/18/20	DST	
0110903-09	Sample Location: GES Library Office / Sink									
Lead (‡)		1030	**37**	ppb	2	15	11/04/20 06:46	12/18/20	DST	
0110903-10	Sample Location: GES Gym / Fountain									
Lead (‡)		1030	ND	ppb	2	15	11/04/20 06:18	12/18/20	DST	
0110903-11	Sample Location: GES Hall / Fountain									
Lead (‡)		1030	ND	ppb	2	15	11/04/20 06:20	12/18/20	DST	
0110903-12	Sample Location: GES Staff Lounge									
Lead (‡)		1030	3	ppb	2	15	11/04/20 06:23	12/18/20	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110903

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
0110903-13	Sample Location: GES Room 101 / Fountain									
Lead (‡)		1030	10	ppb	2	15	11/04/20 06:26	12/18/20	DST	
0110903-14	Sample Location: GES Room 104 / Fountain									
Lead (‡)		1030	11	ppb	2	15	11/04/20 06:28	12/18/20	DST	
0110903-15	Sample Location: GES Room 106 / Fountain									
Lead (‡)		1030	4	ppb	2	15	11/04/20 06:30	12/18/20	DST	
0110903-16	Sample Location: GES Room 105 / Fountain									
Lead (‡)		1030	4	ppb	2	15	11/04/20 06:30	12/18/20	DST	
0110903-17	Sample Location: GES Room 107 / Fountain									
Lead (‡)		1030	ND	ppb	2	15	11/04/20 06:34	12/18/20	DST	
0110903-18	Sample Location: GES Room 108 / Fountain									
Lead (‡)		1030	6	ppb	2	15	11/04/20 06:34	12/18/20	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 0110903

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager