UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 1021705

Glendale School District 77	Project: General	Date Reported: 03/04/21
PO Box E/10598	Project #: Glendale High School	Date Received: 02/17/21 09:10
Glendale, OR 97442		Sampled By: Clinton Crites
	Client Contact: Clinton Crites	

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
1021705-01	Sample Location: 20000200-KF00621A / Kitchen Hand Sink Rear									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:09	02/26/21	DST	
1021705-02	Sample Location: 20000200-BF00721A / Kitchen Restroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:09	02/26/21	DST	
1021705-03	Sample Location: 20000200-BF00921A / West Hall Girls RR RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:11	02/26/21	DST	
1021705-04	Sample Location: 20000200-BF01021A / West Hall Girls RR LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:11	02/26/21	DST	
1021705-05	Sample Location: 20000200-BF01121A / West Hall Boys RR RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:13	02/26/21	DST	
1021705-06	Sample Location: 20000200-BF01221A / West Hall Boys RR LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:13	02/26/21	DST	
1021705-07	Sample Location: 20000200-BF01421A / Team Room LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:16	02/26/21	DST	
1021705-08	Sample Location: 20000200-BF01521A / Team Room RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:16	02/26/21	DST	
1021705-09	Sample Location: 20000200-BF01721A / Girls Locker Room LT Sink									
Lead (‡)		1030	3.0	ppb	1.0	15	02/12/21 07:18	02/26/21	DST	
1021705-10	Sample Location: 20000200-BF01821A / Girls Locker Room RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:18	02/26/21	DST	
1021705-11	Sample Location: 20000200-BF02021A / Boys Locker Room LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:20	02/26/21	DST	
1021705-12	Sample Location: 20000200-BF02121A / Boys Locker Room RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:20	02/26/21	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 1021705

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
1021705-13	Sample Location: 20000200-IM02421B / HS Ice Machine									
Lead (‡)		1030	1.0	ppb	1.0	15	02/12/21 07:28	02/26/21	DST	
1021705-14	Sample Location: 20000200-BF02521A / Women's Staff RR									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:31	02/26/21	DST	
1021705-15	Sample Location: 20000200-BF02621A / Men's Staff RR									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:31	02/26/21	DST	
1021705-16	Sample Location: 20000200-SF02921A / Counseling Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:32	02/26/21	DST	
1021705-17	Sample Location: 20000200-NS03021A / Nurses Office Sink									
Lead (‡)		1030	1.0	ppb	1.0	15	02/12/21 07:33	02/26/21	DST	
1021705-18	Sample Location: 20000200-BF03121A / East Boys RR LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:39	02/26/21	DST	
1021705-19	Sample Location: 20000200-BF03221A / East Boys RR Center Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:39	02/26/21	DST	
1021705-20	Sample Location: 20000200-BF03321A / East Boys RR RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:39	02/26/21	DST	
1021705-21	Sample Location: 20000200-BF03521A / East Girls RR LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:37	02/26/21	DST	
1021705-22	Sample Location: 20000200-BF03621A / East Girls RR Center Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:37	02/26/21	DST	
1021705-23	Sample Location: 20000200-BF03721A / East Girls RR RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:37	02/26/21	DST	
1021705-24	Sample Location: 20000200-BF04521A / Room H2 Bathroom Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:42	02/26/21	DST	
1021705-25	Sample Location: 20000200-CF04621A / Room HS Class Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:42	02/26/21	DST	
1021705-26	Sample Location: 20000200-BF04721A / HS Shops Boys RR Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:03	02/26/21	DST	
1021705-27	Sample Location: 20000200-BF04821A / HS Shops Girls RR Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 1021705

Method: EPA 200.8 Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:03	02/26/21	DST	
1021705-28	Sample Location: 20000500-KF00121B / Football Concessions Sink									
Lead (‡)		1030	2.6	ppb	1.0	15	02/12/21 08:06	02/26/21	DST	
1021705-29	Sample Location: 20000500-BF00221A / Football Mens RR Sink									
Lead (‡)		1030	2.7	ppb	1.0	15	02/12/21 08:01	02/26/21	DST	
1021705-30	Sample Location: 20000500-BF00321A / Football Womens RR Sink									
Lead (‡)		1030	2.1	ppb	1.0	15	02/12/21 08:02	02/26/21	DST	
1021705-31	Sample Location: 20000500-KF00421B / Softball Concessions Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 08:15	02/26/21	DST	
1021705-32	Sample Location: 20000500-IM00521A / Football Concessions Ice Machine									
Lead (‡)		1030	5.0	ppb	1.0	15	02/12/21 08:02	02/26/21	DST	
1021705-33	Sample Location: 20000500-DW00821A / Baseball Home Dugout Fountain									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 08:02	02/26/21	DST	
1021705-34	Sample Location: 20000500-DW00921A / Baseball Guest Dugout Fountain									
Lead (‡)		1030	1.1	ppb	1.0	15	02/12/21 08:10	02/26/21	DST	
1021705-35	Sample Location: 20000400-CF00121A / Room J2 Sink LT									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:51	02/26/21	DST	
1021705-36	Sample Location: 20000400-CF00221A / Room J2 Sink RT									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:51	02/26/21	DST	
1021705-37	Sample Location: 20000400-BF00321A/ Boys RR LT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:53	02/26/21	DST	
1021705-38	Sample Location: 20000400-BF00421A/ Boys RR RT Sink									
Lead (‡)		1030	1.0	ppb	1.0	15	02/12/21 07:53	02/26/21	DST	
1021705-39	Sample Location: 20000400-BF00521A/ Girls RR LT Sink									
Lead (‡)		1030	2.0	ppb	1.0	15	02/12/21 07:54	02/26/21	DST	
1021705-40	Sample Location: 20000400-BF00621A/ Girls RR RT Sink									
Lead (‡)		1030	ND	ppb	1.0	15	02/12/21 07:54	02/26/21	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager

UMPQUA Research Company
626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT
URC # 1021705

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.
This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager